COOPER TESTING LABORATORY

Corrosivity Test Summary

CTL # _____ **Date:** _____ **Tested By:** PJ **Checked:** PJ

Client: _____ **Project:** _____ **Proj. No:** _____

Remarks:

Sample Location or ID			Resistivity @ 15.5 °C (Ohm-cm)			Chloride	Sulfate		pH	ORP	Moisture	Soil Visual Description
Boring	Sample, No.	Depth, ft.	As Rec.	Minimum	Saturated	mg/kg	mg/kg	%		(Redox)	At Test	
						Dry Wt.	Dry Wt.	Dry Wt.		mv	%	
			ASTM G57	Cal 643	ASTM G57	Cal 422-mod.	Cal 417-mod.	Cal 417-mod.	Cal 643	SM 2580B	ASTM D2216	
B-1	-	2.5	-	1651	-	16	130	0.0130	8.7	-	11.1	Reddish Brown Clayey SAND w/ Gravel
B-3	-	11	-	1439	-	51	109	0.0109	7.9	-	31.5	Yellowish Brown CLAY w/ Sand