



**Minimum & Maximum Index Unit Weight
ASTM D4254 & ASTM D4253**

CTL Job No.: _____
Client: _____
Project Name: _____
Project No.: _____

Boring: _____
Sample: _____
Depth (ft.): _____

Date: _____
Tested : PJ
Checked: DC

Visual Description: Gray GRAVEL

INDEX UNIT WEIGHT TEST RESULTS

Minimum Index Unit Wt., pcf **87.2**

Maximum Index Unit Wt., pcf **109.0**

GRADATION TEST RESULTS

Gradation As Received			
Sieve #	Wt. Retained	% Retained	% Finer
3"	-	-	-
1 1/2"	-	-	-
3/4"	-	-	-
1/2"	-	-	-
3/8"	-	-	-
#4	-	-	-

Testing Remarks

Minimum Index Unit Weight:

Test Method used: B
Size of mold used (ft³): 0.1
Remarks: Method B - Soil Filled Tube.

Maximum Index Unit Weight:

Test Method used: 1B
Size of mold used (ft³): 0.1
Remarks: Method 1B - Wet Soil.