Corrosivity Test Summary

CTL # _____ Date: _____ Tested By: _____ Checked: _____

Client: _____ Project: _____ Proj. No: _____

Remarks:

Sample Location or ID			Resistivity @ 15.5 °C (Ohm-cm)			Chloride	Sulfate-(water soluble)		pH	ORP	Moisture	Soil Visual Description
Boring	Sample, No.	Depth, ft.	As Rec.	Minimum	Saturated	mg/kg	mg/kg	%		(Redox)	As Received	
						Dry Wt.	Dry Wt.	Dry Wt.		mv	%	
			ASTM G57	Cal 643	ASTM G57	Cal 422-mod.	Cal 417-mod.	Cal 417-mod.	ASTM G51	SM 2580B	ASTM D2216	
EB-10	3B	6.0	-	-	3,295	-	-	-	-	-	-	Brown SAND with Clay
EB-12	3B	14.5	-	-	1,943	-	-	-	-	-	-	Brown Sandy CLAY
#1	-	-	-	-	1,841	-	-	-	-	-	-	Greenish Gray Clayey SAND
#2	-	-	-	-	2,392	-	-	-	-	-	-	Greenish Gray Clayey SAND
#3	-	-	-	-	6,210	-	-	-	-	-	-	Reddish Brown Clayey SAND with Gravel
#4	-	-	-	-	5,755	-	-	-	-	-	-	Brown Clayey SAND