



Sand Equivalent Test Report
Caltrans Test Method 217
Cooper Testing Labs, Inc.

Job No.: _____ Date: _____
Client: _____ By: MD
Project: _____ Checked By: PJ
Sample # _____ Source: _____
Soil Description: Grayish Brown GRAVEL w/ Silt & Sand

Trial:	#1	#2
Height of Sand:	<u>29</u>	<u>30</u>
Clay Reading @ 20 min.:	<u>41</u>	<u>42</u>
Sand Equivalent:	<u>71</u>	<u>72</u>
Average Sand Equivalent:	<u>72</u>	

Remarks: Sample oven dried.

- Notes:
1. Test must be run in duplicate.
 2. Sand equivalent of specimens must agree within 4 points.
 3. If sand equivalent of an air dried sample does not meet the specification requirement, the test must be repeated using an oven dry sample.